



HAYES

CONSTRUCTION SERVICES

REQUEST FOR INFORMATION		Date Issued:	2-6-19
Contractor Bid Phase		Reply Requested by:	
TO: Carmina-Wood-Morris Architects Joe Dorobiala Phone: 716-842-3165 x 107 Email: jdorobiala@CWM-AE.COM		Request for Information #:	7
		Project Number:	
		Copy to: Jeff Hayes jeff@hayesbuild.com	
		Number of Pages:	
From: Hayes Construction Services 656 Genesee Street Buffalo NY 14221 Mark Brautlacht Phone: 716-768-0145 Email: mark@hayesbuild.com		Project: West End Townhouses Lakefront Blvd. Buffalo, New York	
List documents researched when seeking the information requested.			
SPECIFICATIONS:	DRAWINGS:	OTHER:	
075301	A-601		

Describe the question or type of information requested:

Spec calls for vapor barrier and overlayment board. Roof and ceiling assembly do not show these items.

Are they required, and if so issue spec product information.

Response:

A vapor barrier is not required for this project, please disregard. Overlayment boards are required for patios, please use Carlisle SecurShield HD Polyiso or approved equal.

