



HAYES

CONSTRUCTION SERVICES

REQUEST FOR INFORMATION Contractor Bid Phase		Date Issued:	6-8-19
		Reply Requested by:	
TO: Carmina-Wood-Morris Architects Joe Dorobiala Phone: 716-842-3165 x 107 Email: jdorobiala@CWM-AE.COM		Request for Information #:	11
		Project Number:	
		Copy to: Jeff Hayes jeff@hayesbuild.com	
		Number of Pages:	
From: Hayes Construction Services 656 Genesee Street Buffalo NY 14221 Mark Brautlacht Phone: 716-768-0145 Email: mark@hayesbuild.com		Project: West End Townhouses Lakefront Blvd. Buffalo, New York	
List documents researched when seeking the information requested.			
SPECIFICATIONS:	DRAWINGS:	OTHER:	
260519 D			

Describe the question or type of information requested:

Is Romex acceptable for rough-in wiring in lieu of MC cable?

Response:

Romex is acceptable for branch circuit wiring.

Robert K Stewart - 02.11.19

