



HAYES

CONSTRUCTION SERVICES

REQUEST FOR INFORMATION Contractor Bid Phase		Date Issued:	2-12-19
		Reply Requested by:	
TO: Carmina-Wood-Morris Architects Joe Dorobiala Phone: 716-842-3165 x 107 Email: jdorobiala@CWM-AE.COM		Request for Information #:	19
		Project Number:	
		Copy to: Jeff Hayes	jeff@hayesbuild.com
		Number of Pages:	
From: Hayes Construction Services 656 Genesee Street Buffalo NY 14221 Mark Brautlacht Phone: 716-768-0145 Email: mark@hayesbuild.com		Project: West End Townhouses Lakefront Blvd. Buffalo, New York	
List documents researched when seeking the information requested.			
SPECIFICATIONS:	DRAWINGS:	OTHER:	

Describe the question or type of information requested:

What is the required STC rating between units?

Response:

We are looking to achieve an STC Rating between 55 and 59.





HAYES
CONSTRUCTION SERVICES



656 Genesee St. ☎ Buffalo NY 14221 ☎ P.716.768.0145 ☎ F.716.235.2610
Jeff@hayesbuild.com ☎ Mindy@hayesbuild.com ☎ www.hayesbuild.com