



HAYES

CONSTRUCTION SERVICES

REQUEST FOR INFORMATION		Date Issued:	2-12-19
Contractor Bid Phase		Reply Requested by:	
TO: Carmina-Wood-Morris Architects Joe Dorobiala Phone: 716-842-3165 x 107 Email: jdorobiala@CWM-AE.COM		Request for Information #:	27
		Project Number:	
		Copy to: Jeff Hayes jeff@hayesbuild.com	
		Number of Pages:	
From: Hayes Construction Services 656 Genesee Street Buffalo NY 14221 Mark Brautlacht Phone: 716-768-0145 Email: mark@hayesbuild.com		Project: West End Townhouses Lakefront Blvd. Buffalo, New York	
List documents researched when seeking the information requested.			
SPECIFICATIONS:	DRAWINGS:	OTHER:	
	A-001		

Describe the question or type of information requested:

Could you specify an alternate UL Design for the load bearing demising wall? We are concerned that the drywall at the inside area will be exposed to weather and will deteriorate while the building is being erected. Can shaft wall be used in lieu of the between-wall GWB?

Response:

We would prefer to keep the specified UL Design as noted in the drawings. However, we accept that the interior layers could be exposed to the weather and propose that we use an exterior grade Type X gypsum sheathing that bears the UL Classification Mark.

