



HAYES

CONSTRUCTION SERVICES

REQUEST FOR INFORMATION		Date Issued:	6-12-19
Contractor Bid Phase		Reply Requested by:	
TO: Carmina-Wood-Morris Architects Joe Dorobiala Phone: 716-842-3165 x 107 Email: jdorobiala@CWM-AE.COM		Request for Information #:	20
		Project Number:	
		Copy to: Jeff Hayes jeff@hayesbuild.com	
		Number of Pages:	
From: Hayes Construction Services 656 Genesee Street Buffalo NY 14221 Mark Brautlacht Phone: 716-768-0145 Email: mark@hayesbuild.com		Project: West End Townhouses Lakefront Blvd. Buffalo, New York	
List documents researched when seeking the information requested.			
SPECIFICATIONS:	DRAWINGS:	OTHER:	
Soil Pipe and Fittings	P-600		

Describe the question or type of information requested:

Per the spec section it calls out for hub and spigot sewer under slab and no-hub cast iron above slab.
Would solid wall Schedule 40 PVC be acceptable

Response:

Solid Wall Schedule 40 PVC is code-compliant per table 702.2 of the International Plumbing Code when installed per manufacturer's recommendations. Verify material acceptance with City of Buffalo Plumbing Inspector.
-David M. Schlant, Jr - 2/14/19





HAYES
CONSTRUCTION SERVICES



656 Genesee St. ☎ Buffalo NY 14221 ☎ P.716.768.0145 ☎ F.716.235.2610
Jeff@hayesbuild.com ☎ Mindy@hayesbuild.com ☎ www.hayesbuild.com