



HAYES

CONSTRUCTION SERVICES

REQUEST FOR INFORMATION		Date Issued:	2-1-19
Contractor Bid Phase		Reply Requested by:	
TO: Carmina-Wood-Morris Architects Joe Dorobiala Phone: 716-842-3165 x 107 Email: jdorobiala@CWM-AE.COM		Request for Information #:	4
		Project Number:	
		Copy to: Jeff Hayes jeff@hayesbuild.com	
		Number of Pages:	
From: Hayes Construction Services 656 Genesee Street Buffalo NY 14221 Mark Brautlacht Phone: 716-768-0145 Email: mark@hayesbuild.com		Project: West End Townhouses Lakefront Blvd. Buffalo, New York	
List documents researched when seeking the information requested.			
SPECIFICATIONS:	DRAWINGS:	OTHER:	
	E-103, E-104, E-105		

Describe the question or type of information requested:

Per note G on E-103, E-104, & E-105 and specification 33 in section 1601: Is there to be a fully monitored fire alarm system in each building or each unit (which will require notification devices) or are the units to be supplied by independent 120 v smoke / co conventional devices ?

Response:

Each unit to be supplied by independent 120V smoke/CO conventional devices. Monitored system is NOT required.

Robert K Stewart - 02.04.19

