

THE BUFFALO AND FORT ERIE PUBLIC BRIDGE
AUTHORITY

ADDENDUM NO. 3

To the

SPECIFICATIONS AND BID DOCUMENTS

*TO FURNISH LABOR, MATERIALS AND
EQUIPMENT FOR THE*



CROSSING PATHS  BUILDING FUTURES
THE PEACE BRIDGE

**R.F. WILLSON BUILDING MECHANICAL AND
ELECTRICAL UPGRADE PROJECT**

April, 2019

Addendum Issued: 5/17/2019

BUFFALO & FORT ERIE
PUBLIC BRIDGE AUTHORITY
WILLSON BUILDING
MECHANICAL & ELECTRICAL UPGRADES

ADDENDUM NO. 3

ITEM 1 – REFERENCE PROJECT MANUAL, SECTION 263620 – ROLL-UP GENERATOR CONNECTION BOX

- Replace: In the specification page footer: replace section designation TRANSFER SWITCHES with ROLL-UP GENERATOR CONNECTION BOX.
- Replace: In the specification page footer: replace section number 263600 with 263620.
- Replace: In the specification section Part 2, sub-paragraph 2.2.C.3 replace “800Amps” rating with “1600Amps”.
- Replace: In the specification section Part 2, sub-paragraph 2.2.F.1.g replace “800A” rating with “1600Amps”.

END OF ADDENDUM NO. 3

JMR/TAN/RKD/AK:ak 05/17/2019