

**WILLSON BUILDING
MECHANICAL AND ELECTRICAL
UPGRADES**

**Buffalo and Fort Erie Public Bridge Authority
Peace Bridge Plaza
Buffalo, New York 14213**

ADDENDUM NO. 4

**TA PROJECT 18023
MAY 17, 2019**

BUFFALO & FORT ERIE
PUBLIC BRIDGE AUTHORITY
WILLSON BUILDING
MECHANICAL & ELECTRICAL UPGRADES

ADDENDUM NO. 4

ITEM 1 – REFERENCE PROJECT MANUAL, SECTION 238219 – WATER SOURCE FAN COIL UNITS

Clarification: Section 2.2M in SS 238219 addresses the factory, hydronic piping package. The controls contractor through the PBA is to provide the piping package with the control valve. The hydronic piping package will then be turned over to the mechanical contractor for installation.

END OF ADDENDUM NO. 4

JMR/TAN/RKD/AK:ak 05/17/2019